

# ADDENDUM #3 CHANGE REQUEST 1/3

**Jeff Vaughan**

---

**From:** wade nash <nash973@gmail.com>  
**Sent:** Thursday, August 1, 2019 9:25 AM  
**To:** Jeff Vaughan  
**Cc:** Daana Denzel  
**Subject:** BCCA Office and Sales  
**Attachments:** Denzel Northwest Line Card.pdf; Substitution request.pdf; ASIArch\_GrilleCeilingWall\_v1.docx; ASI Wood Projects.docx

Jeff,

Find attached a substitution request for the wood grille specified for this project. As you know there are numerous manufacturers of wood grille, all of which are basically the same. With that being said, the most important components then become quality, service and price. ASI meets that criteria. I have attached information that will assist you in making your decision. If you have any questions feel free to contact me or Daana Denzel of Denzel NW. Daana is the owner of Denzel NW which is a women owned small business and would be happy to meet with you to discuss this product or any of the other material manufacturers she represents. Her line card is attached.

Wade A Nash  
425-977-9693 Cell  
509-548-9978

# ADDENDUM #3 CHANGE REQUEST 2/3

Bellevue Convention Center Authority  
Meydenbauer Center Admin Office and Sales Hub Remodel  
2019-08  
June 18, 2019

Section 01 78 36  
**APPENDIX A: DIVISION 00 / 01 FORMS**

## SUBSTITUTION REQUEST FORM

Project: BCCA Office and Sales Architect's Project Number: \_\_\_\_\_  
To: Jeff Vaughan - Meydenbauer Substitution Request Number: \_\_\_\_\_  
Re: Sub request Date: 8/01/2019  
From: Denzel NorthWest www.denzelnw.com  
Contract For: \_\_\_\_\_

Section Title: Finish Schedule Description: WS1 Panel Grill Wood Slats by Rulon  
Section No.: Plan A4.1 Page: 1 Article/Paragraph: \_\_\_\_\_

Proposed substitution: Panel Grill Wood Slats by ASI  
Manufacturer: ASI Address: 123 Columbia Ct N Chaska, Mn 55318 Phone: 888-258-4637  
Trade Name: ASI Grille Model No./Color: No Model - Color per spec  
Installer: \_\_\_\_\_ Address: \_\_\_\_\_ Phone: \_\_\_\_\_  
History:  New Product  1 - 4 years old  5 - 10 years old  More than 10 years old  
Differences between proposed substitution and specified product: no significant difference

Point-by-point comparative data attached – REQUIRED BY ARCHITECT

Reason for not providing specified item: \_\_\_\_\_

Similar Installation: See attached

Project: \_\_\_\_\_ Architect: \_\_\_\_\_  
Address: \_\_\_\_\_ Owner: \_\_\_\_\_  
Date Installed: \_\_\_\_\_

Proposed substitution affects other parts of Work:  No  Yes; explain \_\_\_\_\_

Savings to Owner for accepting substitution: Product cost is normally cheaper (\$ \_\_\_\_\_).

Proposed substitution changes Contract Time:  No  Yes [Add] [Deduct] \_\_\_\_\_ days.

# ADDENDUM #3 CHANGE REQUEST 3/3

Bellevue Convention Center Authority  
Meydenbauer Center Admin Office and Sales Hub Remodel  
2019-08  
June 18, 2019

Section 01 78 36  
**APPENDIX A: DIVISION 00 / 01 FORMS**

Supporting Data Attached:  Drawings  Product Data  Samples  Tests  
 Reports  Sustainability Criteria

The Undersigned certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product including meeting LEED credit requirements, where applicable
- Same warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Cost data as stated above is complete. Claims for additional costs related to accepted substitution which may subsequently become apparent are to be waived.
- Proposed substitution does not affect dimensions and functional clearances.
- Payment will be made for changes to building design, including A/E design, detailing and construction costs caused by the substitution.
- Coordination, installation, and changes in the Work as necessary for accepted substitution will be correct in all respects.

Submitted by: Wade A Nash  
Signed by: Wade A Nash  
Firm: Denzel NorthWest www.denzelnw.com  
Address: 2415 82nd Ave NE, Medina, WA 98039  
Telephone: 206-669-4600  
Attachments: Spec, detail, etc

## ARCHITECT'S REVIEW AND ACTION

- Substitution approved – Make submittals per Division 01 Section "Substitution Procedures."  
 Substitution approved as noted – Make submittals per Division 01 Section "Substitution Procedures."  
 Substitution rejected – Use specified materials.  
 Substitution Request received too late – Use specified materials.

Signed by: Blair Kodman Date: 2019-08-14

Additional Comments:  Contractor  Subcontractor  Supplier  Manufacturer  A/E  
 Other \_\_\_\_\_

### SKB Substitution Notes: Blair Kodman

1. Must have black fabric backer per manufacturer.
2. Must adhere to specified width and depth
3. Must provide sample of walnut finish for approval – provide alt. for custom stain
4. Must adhere to specified spacing between wood slats.