



## Walk-In Cooler Questions & Answers

**Question:** *The floor under the cooler was mentioned in the scope to have leaked. What will need to be done?*

**Answer:** Per the scope a waterproof membrane will need to be installed

**Question:** *Who did the sprinkler system at Meydenbauer?*

**Answer:** Our current contractor for the sprinkler system is Viking Sprinkler

**Question:** *How do the panels get upstairs to the 4<sup>th</sup> floor?*

**Answer:** The service elevator in the loading dock and it comes up to the 4<sup>th</sup> floor kitchen. It is big enough to handle the panels

**Question:** *What happens to the old panels?*

**Answer:** It is up to the contractor to dispose of all demoed equipment and material. Meydenbauer would encourage recycling or repurposing the panels.

**Question:** *Is the rooftop unit directly above the cooler box?*

**Answer:** No, the rooftop unit is not directly above but rather off to the side about 10-20'

**Question:** *Can the construction crew park here?*

**Answer:** Yes, the successful bidder will receive instructions on how to park onsite in the north lot for free and how to check in with security.

**Question:** *Is this project prevailing wage?*

**Answer:** Yes. All projects at Meydenbauer Center are prevailing wage.

**Question:** *How old is the existing cooler?*

**Answer:** About 30 years.